



OFFICE OF THE CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT DRINKING WATER TESTING LABORATORY, PALWAL
9MLD STP, JODHPUR ROAD, PALWAL, HARYANA - 121102

E-mail:-chemist.palwal@phedharyana.gov.in, chemist.palwal@gmail.com Haryana

PHED

TEST REPORT

Customer Name & Contact: → SPS International School
Test Report No. : → PWL/04326/2/2026
Reference No. : → SPSJ/3972 /dt.01/10/2026
Sample Type : → R.O.
Test Type : → Physical Chemical Test
Classification of Sample : → Private
Sample Description : → Drinking Water

Location: → HUDA Sec - 2 Palwal
Collected by: → Harish Kumar
Sample collected Date & Time : → 01/10/2026 at 11 :26
Sample received Date & Time: → 01/10/2026 at 11 :26
Date of Analysis Started : → 01/10/2026 at 11 :26
Date of Analysis Completed : → 01/10/2026 at 11 :26
Sample Quantity : → 1000 ml
Issue Date of Report:- 01/10/2026 at 11 :26
Addition/Deviation/ Exclusions from the method :- NA
Environmental Condition:- Temp. (°C) : 25°± 5°
RH (%) : 60± 15%

Test Result

Sr. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012 RA 2018	
					Acceptable	Permissible Limit
1.	Turbidity	<1	NTU	APHA 24th Edition 2130-B	1 NTU	5 NTU
2.	Taste	Agreeable	---	IS 3025 (Part-8) 1984:RA 2023	Agreeable	Agreeable
3.	Odour	Agreeable	---	IS 3025 (Part-5) 1983:2018	Agreeable	Agreeable
4.	Colour	<5	CU	APHA 24th Edition-2120-B	5 CU	15 CU
5.	Total Dissolve Solids (180°C ± 2°C)	180	mg/l	APHA 24th Edition-2540 C	500 mg/l	2000 mg/l
6.	Total Hardness as CaCO ₃	40	mg/l	APHA 24th Edition-2340 C	200 mg/l	600 mg/l
7.	Calcium as (Ca)	7.21	mg/l	APHA 24th Edition-3500-Ca B	75 mg/l	200 mg/l
8.	Magnesium (Mg)	5.34	mg/l	APHA 24th Edition-3500-Mg B	30 mg/l	100 mg/l
9.	Total Alkalinity	24	mg/l	APHA 24th Edition-2320 B	200 mg/l	600 mg/l
10.	Chlorides as Cl	33.98	mg/l	APHA 24th Edition-4500 Cl B	250 mg/l	1000 mg/l
11.	Sulphate as (SO ₄)	15	mg/l	APHA 24th Edition-4500-SO ₄ E	200 mg/l	400 mg/l
12.	Fluoride as (F)	0.15	mg/l	APHA 24th Edition-4500-F D	1.0 mg/l	1.5 mg/l
13.	Iron as (Fe)	0.01	mg/l	APHA 24th Edition-3500-Fe B	1.0 mg/l	No Relaxation
14.	Nitrate as (NO ₃)	2.8	mg/l	APHA 24th Edition-4500-NO ₃ D	45 mg/l	No Relaxation
15.	pH (@25°C)	6.95	---	APHA 24th Edition-4500-H B	6.5-8.5	No Relaxation

Remarks:-

Specific contractual notes:-

- ♦ The results given above are related to the sample as received and tested in PHED Lab PALWAL.
- ♦ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of the Chemist, Palwal.
- ♦ The test report can't be used for any publicity or any legal purpose.
- ♦ Reliability of water sample lies with sender/collector of water sample.
- ♦ The Samples will be destroyed after retention time of 15 days unless specifies otherwise.

Principal
SPS INTERNATIONAL
Sector-2, HUDA
PALWAL

CHANDRENA
PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY
PALWAL

END OF REPORT

From Assistant Divisional Fire Officer/Fire Station Officer
PALWAL

To M/s SPS INTERNATIONAL SCHOOL
HUDA SEC 2 PALWAL

Memo No. FS/2024/7 dated : 06/02/2024

Subject: Renewal of Fire Safety Certificate 15 mtrs. and Above height from the fire Safety Point of View of the Group B-Educational Building at HUDA SEC 2 PALWAL of SPS INTERNATIONAL SCHOOL :

Reference to you online No 211162423000021 dated 19/01/2024 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
SPS INTERNATIONAL SCHOOL	G+3	12	6948.488

Basement Level	Basement Area	Remarks
1	2368.508	ok

Your site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, **PALWAL** from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 4) You are directed to apply for Renewal of Fire Safety Certificate in future before 2 month of expiry of your Fire Safety Certificate.
- 5) The open set back area is not checked at our end as it shall be checked by concerned building department.
- 6) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 30,31 & 47 of fire & Emergency Services Act 2022.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 9) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Renewal of Fire Safety Certificate is valid for **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- ok



Mamta
PRINCIPAL
SPS INTERNATIONAL
HUDA SEC.-2, PALWAL

Mamta
Principal
SPS INTERNATIONAL
Sector-2, HUDA
PALWAL

FIRE OFFICER

PALWAL

Exercising t




Digitally signed by RAM DUTT
of Haryana Fire Services, Haryana
Date: 2024.02.06 10:29:40 +05:30
Reason: Digital Verification

Health&Hygiene Certificate

In pursuance of the application SPS International School, Huda Sec-2, Palwal (Haryana) in the O/o Civil Surgeon, Palwal. The school premises were inspected by team of Health Department palwal. The school was found to have satisfactory hygiene conditions as per the standard checklist of the District. This certificate is valid up to 31-03-2027.

Date of Renewal:- 01-04-2027


Civil Surgeon
Palwal


Dy. Civil Surgeon (School Health)
Palwal


Principal
SPS INTERNATIONAL
Sector-2, HUDA.
PALWAL

ANNEXURE D

BUILDING SAFETY CERTIFICATE

No.

1653

Dated: 11/05/26

It is certified that the existing building SPS INTERNATIONAL (Society- SPS EDUCATIONAL TRUST) at HUDA SEC-2, PALWAL is having block(s)/Floor(s) as per details below:

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	G+3					

The building is owned/occupied by SPS INTERNATIONAL (Society- SPS EDUCATIONAL TRUST) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PWD B&R (Name of Department/ Govt.) on 30.04.2026 (date of inspection) in the presence of Principal, SPS INTERNATIONAL (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 01-04-2026 for a period of 2026-2027 years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.
- 2.
- 3.
- 4.

Issued on 30.04.2026 PALWAL by Sub Divisional Engineer, Provincial Sub Division, PWD B&R Br. Palwal

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Mamta
Principal
SPS INTERNATIONAL
Sector-2, HUDA
PALWAL

Siddharth Dev
Sub Divisional Engineer
Provincial Sub Division
Signature with Seal: PWD B & R Branch Palwal
Name: SIDDHARTH DEV
Designation: Sub Divisional Engineer,
Provincial Sub Division,
Name & Address of Department/ Office: PWD B&R Br., Palwal